



## PAC (POLYALUMINIUM CHLORIDE)

<b>PRODUCT NAME:</b>	<b>Poly Aluminium Chloride FOR DRINKING WATER TREATNEBT (SOLID)</b>	<b>INSPECTION STANDARD</b>	<b>GB15892-2009</b>
<b>BATCH NO</b>	<b>SDTJ161118</b>	<b>Inspection Date</b>	<b>2016-11-18</b>
<b>Manufacture Date</b>	<b>2016-11-18</b>	<b>Expiry Date</b>	<b>2018-11-18</b>
<b>TESTING ITEM</b>		<b>INDEX</b>	<b>Results</b>
<b>Aluminium Oxide (Al<sub>2</sub>O<sub>3</sub>) CONTENT</b>		<b>30.0%MIN</b>	<b>30.55%</b>
<b>Basicity %</b>		<b>40.0%-90.0%</b>	<b>83.0%</b>
<b>PH VALUE(1% aqueous solution)</b>		<b>3.5-5.0</b>	<b>4.0</b>
<b>Water insoluble matter</b>		<b>0.6%MAX</b>	<b>0.39%</b>
<b>Fe Content</b>		<b>0.2%MAX</b>	<b>0.15%</b>
<b>As Content</b>		<b>0.0002%MAX</b>	<b>0.00018%</b>
<b>Cd Content</b>		<b>0.0002%MAX</b>	<b>0.00016%</b>
<b>Cr 6+ Content</b>		<b>0.0005%MAX</b>	<b>0.0003%</b>
<b>Pb Content</b>		<b>0.001%MAX</b>	<b>0.0008%</b>
<b>Hg Content</b>		<b>0.00001%MAX</b>	<b>0.000006%</b>

QUALITY:WE CAN ASSURE POLY ALUMINIUM CHLORIDE FOR DRINKING WATER TREATMENT (SOLID) HAS REACHED A VERY HIGH QUALITY AFTER USING GB15892-2009 TESTING METHOD

Product Name : PAC

Commercial Name :

Date:

Page Number : 1

**KANGAROO**

Unit3, NO 14,Yas Alley, Below Hemmat Highway,  
South Shiraz St, Tehran, IRAN

**Website** : [www.yeskangaroo.com](http://www.yeskangaroo.com)

**Email** : [info@yeskangaroo.com](mailto:info@yeskangaroo.com)